

CERTIFICATE OF COMPLIANCE

Certificate Number 20130513 – EX15258
Report Reference EX4326 - 19930504
Issue Date 2013-May-13

Issued to: AMERICAN AVK CO
Listed Company: 2155 MERIDIAN BLVD
MINDEN NV 89423

Manufacturer: AVK INTERNATIONAL A/S
SMEDESKOVVEJ 40
8464 GALTEN DENMARK


**This is to certify that
representative samples of** Hydrants
Base Valve Design

Model	Rated Pressure (psig)
2700 (Modem)	250
2780 (Nostalgic)	250
2756 (Nostalgic)	250
27DA (Modem)	250


Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 246, Hydrants for Fire-Protection Service
Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20170223 – EX15258
Report Reference EX4326 – 19930504
Issue Date 2017-FEBRUARY-23

Issued to: AMERICAN AVK CO
Applicant Company: 2155 MERIDIAN BLVD
MINDEN, NV 89423-8601 USA

Listed Company: AVK Armaturen GmbH
Schillerstrasse 50
POSTFACH 1440
42489 Wuelfrath GERMANY

**This is to certify that
representative samples of** Hydrants
Base Valve Design

Model	Rated Pressure (psig)
2700 (Modern)	250
2780 (Nostalgic)	250
2756 (Nostalgic)	250
27DA (Modern)	250

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 246, "Hydrants for Fire-Protection Service."
Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130513 – EX15258
Report Reference EX4326 - 19930504
Issue Date 2013-May-13

Issued to: AMERICAN AVK CO
Listed Company: 2155 MERIDIAN BLVD
MINDEN NV 89423

Manufacturer: AMERICAN AVK CO
2155 MERIDIAN BLVD
MINDEN NV 89423


**This is to certify that
representative samples of** Hydrants
Base Valve Design

Model	Rated Pressure (psig)
2700 (Modern)	250
2780 (Nostalgic)	250
2756 (Nostalgic)	250
27DA (Modern)	250


Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 246, Hydrants for Fire-Protection Service
Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130513 – EX15258
Report Reference EX4326 - 19930504
Issue Date 2013-May-13

Issued to: AMERICAN AVK CO
Listed Company: 2155 MERIDIAN BLVD
MINDEN NV 89423

Manufacturer: SAUDI VALVE MFG CO LTD
INDUSTRIAL AREA PHASE 4
ROAD 404
PO BOX 10830
JEDDAH 21443 SAUDI ARABIA


**This is to certify that
representative samples of** Hydrants
Base Valve Design

Model	Rated Pressure (psig)
2700 (Modern)	250
2780 (Nostalgic)	250
2756 (Nostalgic)	250
27DA (Modern)	250


Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 246, Hydrants for Fire-Protection Service
Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

